

FCC Form 481, Line 610: Certification Regarding Ability to Function in Emergency Situations

Iowa Administrative Code §199-22.6(5) requires an ETC to certify in its annual report that it is complying with provisions to meet emergencies including but not limited to the provision of emergency power. Each central office shall contain a minimum of two hours of battery reserve and for offices without permanently installed emergency power facilities, there shall be access to a mobile power unit with enough capacity to carry the load which can be delivered on reasonably short notice and readily connected. Butler-Bremer Mutual Telephone Company certifies that it has complied with these requirements and will continue to comply with these requirements.